

Citation for published version:

Taormina, R, Galelli, S, Tippenhauer, NO, Salomons, E, Ostfeld, A, Eliades, DG, Aghashahi, M, Sundararajan, R, Pourahmadi, M, Banks, MK, Brentan, BM, Campbell, E, Lima, G, Manzi, D, Ayala-Cabrera, D, Herrera, M, Montalvo, I, Izquierdo, J, Luvizotto, E, Chandy, SE, Rasekh, A, Barker, ZA, Campbell, B, Shafiee, ME, Giacomoni, M, Gatsis, N, Taha, A, Abokifa, AA, Haddad, K, Lo, CS, Biswas, P, Fayzul, M, Kc, B, Somasundaram, SL, Housh, M & Ohar, Z 2018, 'Battle of the Attack Detection Algorithms: Disclosing cyber attacks on water distribution networks', *Journal of Water Resources Planning and Management*, vol. 144, no. 8, 04018048. [https://doi.org/10.1061/\(ASCE\)WR.1943-5452.0000969](https://doi.org/10.1061/(ASCE)WR.1943-5452.0000969)

DOI:

[10.1061/\(ASCE\)WR.1943-5452.0000969](https://doi.org/10.1061/(ASCE)WR.1943-5452.0000969)

Publication date:

2018

Document Version

Peer reviewed version

[Link to publication](#)

© ASCE 2018.

University of Bath

Alternative formats

If you require this document in an alternative format, please contact:
openaccess@bath.ac.uk

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

1 **THE BATTLE OF THE ATTACK DETECTION ALGORITHMS:**
2 **DISCLOSING CYBER ATTACKS ON WATER DISTRIBUTION**
3 **NETWORKS**

4 Riccardo Taormina¹, Stefano Galelli², Member, ASCE, Nils Ole Tippenhauer³, Elad Salomons⁴,
 Avi Ostfeld⁵, Fellow, ASCE, Demetrios G. Eliades⁶, Mohsen Aghashahi⁷, S.M., ASCE,
 Raanju Sundararajan⁸, Mohsen Pourahmadi⁹, M. Katherine Banks¹⁰, Fellow, ASCE,
 B. M. Brentan¹¹, Enrique Campbell¹², G. Lima¹³, D. Manzi¹⁴, D. Ayala-Cabrera¹⁵,
 M. Herrera¹⁶, I. Montalvo¹⁷, J. Izquierdo¹⁸, E. Luvizotto Jr.¹⁹, Sarin E. Chandy²⁰,
Amin Rasekh²¹, Member, ASCE, Zachary A. Barker²², Bruce Campbell²³, M. Ehsan Shafiee²⁴,
Marcio Giacomoni²⁵, Nikolaos Gatsis²⁶, Ahmad Taha²⁷, Ahmed A. Abokifa²⁸, S.M., ASCE,
Kelsey Haddad²⁹, Cynthia S. Lo³⁰, Pratim Biswas³¹, M. Fayzul K. Pasha³², Bijay Kc³³,
Saravanakumar Lakshmanan Somasundaram³⁴, Mashor Housh³⁵, Ziv Ohar³⁶

ABSTRACT

The BATtle of the Attack Detection ALgorithms (BATADAL) is the most recent competition on planning and management of water networks undertaken within the Water Distribution

¹Singapore University of Technology and Design, 8 Somapah Road, Singapore, 487372.

²Singapore University of Technology and Design, 8 Somapah Road, Singapore 487372. E-mail: stefano_galelli@sutd.edu.sg

³Singapore University of Technology and Design, 8 Somapah Road, Singapore 487372.

⁴OptiWater, 6 Amikam Israel St., Haifa 3438561, Israel.

⁵Faculty of Civil and Environmental Engineering, Technion–Israel Institute of Technology, Haifa 32000, Israel.

⁶KIOS Research and Innovation Center of Excellence, University of Cyprus, 75 Kallipoleos Avenue, CY-1678, Nicosia, Cyprus.

⁷Zachry Dept. of Civil Engineering, Texas A&M Univ., College Station, TX.

⁸Dept. of Statistics, Texas A&M Univ., College Station, TX.

⁹Dept. of Statistics, Texas A&M Univ., College Station, TX.

¹⁰Zachry Dept. of Civil Engineering, Texas A&M Univ., College Station, TX.

¹¹CRAN, Universitet de Lorraine, Nancy, France.

¹²Universitat Politècnica de València, Valencia, Spain, Berliner Wasserbetriebe, Berlin, Germany.

¹³Universidade Estadual de Campinas, Campinas, Brazil.

¹⁴Universidade Estadual de Campinas, Campinas, Brazil.

¹⁵Irstea, Cestas, France.

¹⁶Univ. of Bath, Bath, U.K.

¹⁷Ingeniousware GmbH, Karlsruhe, Germany.

¹⁸Universitat Politècnica de València, Valencia, Spain.

¹⁹Universidade Estadual de Campinas, Campinas, Brazil.

²⁰Sensus Inc., 8601 Six Forks Rd., Suite 700, Raleigh, NC 27615.

²¹Sensus Inc., 8601 Six Forks Rd., Suite 700, Raleigh, NC 27615.

²²Sensus Inc., 8601 Six Forks Rd., Suite 700, Raleigh, NC 27615.

²³Sensus Inc., 8601 Six Forks Rd., Suite 700, Raleigh, NC 27615.

²⁴Sensus Inc., 8601 Six Forks Rd., Suite 700, Raleigh, NC 27615.

²⁵Dept. of Civil and Environmental Engineering, Univ. of Texas at San Antonio, San Antonio, TX 78249.

²⁶Dept. of Electrical and Computer Engineering, Univ. of Texas at San Antonio, San Antonio, TX 78249.

²⁷Dept. of Electrical and Computer Engineering, Univ. of Texas at San Antonio, San Antonio, TX 78249.

²⁸Dept. of Energy, Environmental, and Chemical Engineering, Washington Univ., St. Louis.

²⁹Dept. of Energy, Environmental, and Chemical Engineering, Washington Univ., St. Louis.

³⁰Dept. of Energy, Environmental, and Chemical Engineering, Washington Univ., St. Louis.

³¹Dept. of Energy, Environmental, and Chemical Engineering, Washington Univ., St. Louis.

³²Dept. of Civil and Geomatics Engineering, California State Univ., Fresno, CA 93740.

³³Dept. of Civil and Geomatics Engineering, California State Univ., Fresno, CA 93740.

³⁴Dept. of Civil and Geomatics Engineering, California State Univ., Fresno, CA 93740.

³⁵Faculty of Management, Dept. of Nat. Res. and Environmental Manag., Univ. of Haifa, Haifa, Israel.

³⁶Faculty of Management, Dept. of Nat. Res. and Environmental Manag., Univ. of Haifa, Haifa, Israel.

Systems Analysis Symposium. The goal of the battle was to compare the performance of algorithms for the detection of cyber-physical attacks, whose frequency increased in the past few years along with the adoption of smart water technologies. The design challenge was set for C-Town network, a real-world, medium-sized water distribution system operated through Programmable Logic Controllers and a Supervisory Control And Data Acquisition (SCADA) system. Participants were provided with datasets containing (simulated) SCADA observations, and challenged with the design of an attack detection algorithm. The effectiveness of all submitted algorithms was evaluated in terms of time-to-detection and classification accuracy. Seven teams participated in the battle and proposed a variety of successful approaches leveraging data analysis, model-based detection mechanisms, and rule checking. Results were presented at the Water Distribution Systems Analysis Symposium (World Environmental & Water Resources Congress), in Sacramento, on May 21-25, 2017. This paper summarizes the BATADAL problem, proposed algorithms, results, and future research directions.

Keywords: Water distribution systems, Cyber-physical attacks, Cyber security, EPANET, Smart water networks, Attack detection

INTRODUCTION

The past decades witnessed the transition of water distribution systems from traditional physical infrastructures to *cyber-physical systems* that combine physical processes with computation and networking: physical assets—such as pipes, pumps, and valves—work in unison with networked devices that monitor and coordinate the operations of the entire system. These devices include Programmable Logic Controllers (PLCs), Supervisory Control And Data Acquisition (SCADA) systems, Remote Terminal Units (RTUs), static and mobile sensor networks, and smart meters (Hill et al. 2014; Gong et al. 2016; Sønderlund et al. 2016). The adoption of such smart water technologies plays a pivotal role in enhancing the automation and reliability of water distribution systems, but simultaneously exposes them to cyber-physical attacks (Rasekh et al. 2016)—namely the deliberate exploitation of computer systems aimed at accessing sensitive information or compromising the operations of

the underlying physical system. Water (and wastewater) systems represent one of the sixteen critical infrastructure sectors identified by the U.S. Department of Homeland Security (U.S. Department of Homeland Security 2017), according to which the number of reported attacks on water infrastructures has been growing steadily (ICS-CERT 2014; ICS-CERT 2015; ICS-CERT 2016)—making them the third highest targeted sector after critical manufacturing and energy (ICS-CERT 2016). To take remedial actions, several countries are establishing research centres and international collaborations, such as the Israel–New York collaboration to defend water systems from "infrastructure terrorists" (The Times of Israel 2018).

Protecting water distribution systems from cyber attacks requires (as with other cyber-physical systems) a combination of proactive and reactive mechanisms (Cardenas et al. 2008). Proactive mechanisms comprise all tools that reduce the chances to penetrate the system, such as appropriate measures for traffic authentication and confidentiality protection, access control, and device hardening (Graham et al. 2016; Adepu et al. 2017). Since it is not possible to rule out all attacks, cyber-physical systems should also be equipped with intrusion detection schemes that assist with the recovery phase (Anderson 2010). Disclosing cyber attacks—without issuing false alarms—is thus crucial. Unfortunately, this does not come without some system-specific challenges. First, the definition of anomalous behaviours should not only be related to point, or content, anomalies—i.e., data points lying beyond some specific thresholds—since cyber-physical attacks can tamper one or multiple network components while keeping the performance characteristics within the historical bounds (Abokifa et al. 2017). This implies that detection schemes should be capable of disclosing both content and contextual anomalies, namely, data points that are considered abnormal when viewed against meta-information associated with the data points (Hayes and Capretz 2015). For example, unaccounted high volumes of water leaving tanks during nighttime, when demand is generally low, may be seen as a contextual anomaly revealed by looking at the flow data in the context of time. Second, the same hydraulic response of a water network (e.g., low water

levels in a tank) can be obtained through different attacks (Taormina et al. 2017). Therefore, detection schemes should also identify the cyber components that have been attacked; a non-negligible challenge in large water networks. Third, all networked devices, including SCADA systems, represent potential targets. This means that the information provided by SCADA systems may not be fully reliable.

As the field of intrusion detection continues to grow, so too does the need of an objective comparison of attack detection algorithms for water distribution systems. The BATtle of the Attack Detection ALgorithms (BATADAL) was organized for this purpose. Participants were provided with datasets containing (simulated) SCADA data for a water distribution system victim of cyber attacks, and were tasked with the design of an attack detection mechanism. The design goals of a detection algorithm were to: (1) disclose the presence of an ongoing attack in the minimum time possible, (2) avoid issuing false alarms, and (3) identify which components of the system have been compromised (optional). Seven teams, from both academia and industry, contributed with novel solutions, which were evaluated using specific evaluation criteria—i.e., time-to-detection and classification accuracy. The BATADAL results were presented at a special session of the Water Distribution Systems Analysis Symposium (World Environmental & Water resources Congress), in Sacramento, on May 21-25, 2017.

This paper summarizes the main solutions and outcomes of the BATADAL, and proposes future research directions for event detection in the realm of cyber-physical security. The remainder of the paper describes: (1) the BATADAL problem, data, and evaluation criteria; (2) a synopsis of the proposed attack detection algorithms; (3) an analysis of the results; and (4) conclusions and future research directions.

PROBLEM DESCRIPTION

The operators of C-Town water distribution system have observed anomalous behaviors

in some hydraulic components, e.g., tank overflows, reduction in pump speed, anomalous activation/deactivation of pumps. They suspect that the anomalies are attributable to cyber-physical attacks that interfered with the system operations and tampered with the readings recorded by the SCADA system. The aim of the participants was to develop an attack detection mechanism that detects the presence of attacks—in the shortest amount of time—from the available hourly SCADA data. In particular, attack detection algorithms must classify the system state as either ‘safe’ or ‘under attack’. A summary description of C-Town is provided below, along with the development data and evaluation criteria. BATADAL rules, problem details, and data are available in the supplemental material of the paper.

C-Town Network

C-Town water distribution system is based on a real-world, medium-sized network, first introduced for the *Battle of the Water Calibration Network* (Ostfeld et al. 2011). The network consists of 429 pipes, 388 junctions, 7 storage tanks, 11 pumps (distributed across 5 pumping stations), 5 valves, and a single reservoir (see Figure 1). Water consumption is fairly regular throughout the year. These physical assets were augmented with a network of nine PLCs, which are located in proximity of pumps, storage tanks, and valves. As shown in Table 1, most of the PLCs controlling the pumps receive the information needed by the control logic from other PLCs—for instance, PLC1 controls pump PU1 and PU2 on the basis of tank T1 water level, which is monitored by PLC2. PLCs controlling pumps and valves record information on the device status (ON/OFF or OPEN/CLOSED), the flow passing through it, and the inlet and outlet pressure of pumping stations. The cyber network includes a SCADA system, whose role is to coordinate the operations and store the readings provided by the PLCs. All information regarding the distribution system were incorporated into the EPANET2 (Rossman 2000) input file *C-Town.inp*, which was provided to the participants. Water demand in all nodes of C-Town was not shared, meaning that participants could not run the model for the same period and then compare the results with the provided SCADA data.

Development data

Participants were provided with three datasets containing SCADA readings for 43 system variables, i.e., tank water levels (7 variables, denoted as $L_{\text{<tank id>}}$), inlet and outlet pressure for one actuated valve and all pumping stations (12 variables, denoted as $P_{\text{<junction id>}}$), as well as their flow and status (24 variables, denoted as $F_{\text{<actuator id>}}$ and $S_{\text{<actuator id>}}$, respectively). All variables are continuous, with the exception of the status of valve and pumps, represented by binary variables. The datasets were generated via simulation with *epanetCPA*, a Matlab toolbox that allows to design a variety of cyber attacks and simulate, with EPANET2 (version 2.0.12), the hydraulic response of a water distribution network (Taormina et al. 2017). The toolbox is available at <https://github.com/rtaormina/epanetCPA>. The hydraulic time step was set to 15 minutes, while the SCADA data reported to the participants were sampled with fixed hourly intervals. The first two datasets, hereafter named *Training dataset 1* and *Training dataset 2*, were provided at the beginning of the competition, while the third one (*Test dataset*) was subsequently used to evaluate and rank the attack detection algorithms.

- *Training dataset 1* was generated with a simulation horizon of 365 days. A key aspect of the dataset is the absence of cyber attacks, which made it suitable for studying the operations of the water distribution system under normal operating conditions.
- *Training dataset 2* contains seven attacks, spanning over 492 hourly time steps. One attack was entirely revealed to the participants (by appropriately labelling the corresponding time steps), while the remaining attacks were either partially revealed or hidden; see Table 2 for additional details. This corresponds to a post-attack scenario, in which forensics experts carry out an investigation to determine whether, when, and where the water distribution system has been affected.
- *Test dataset* contains seven additional attacks, spanning over 407 hourly time steps (see Table 3). Naturally, no information regarding the attacks was revealed. Participants were required to run the detection algorithms on the *Test dataset* and to submit

a detection report containing the following information: number of attacks detected, start and end time of each attack (in *DD-MM-YYYY hh* format), and the label of the attacked device(s) (optional).

The operations of the water system were altered through malicious activation of hydraulic actuators, change of actuator settings, and *deception* attacks—amongst the most common for cyber-physical systems (Cardenas et al. 2009). The latter were aimed at manipulating the information sent or received by sensors and PLCs, with the ultimate goal of affecting the operations of an actuator (Urbina et al. 2016). Note that deception attacks were also used to alter the information received by SCADA, therefore concealing the real, physical outcomes of the attacks. SCADA concealment was performed by either adding an offset to the transmitted sensor readings or by replacing actual traffic information between PLCs and SCADA with previously-recorded data, a type of manipulation known as *replay attack* (Urbina et al. 2016). The replay attacks featured in the BATADAL consisted in replacing data for a given hour of the day with those recorded during the same hour one or two days before. Figure 2 illustrates attack #3 (Training dataset 2), where both pump operations and SCADA data are compromised. In this case, a deception attack manipulates Tank T1 water level readings sent by PLC2 to PLC1. PLC1 receives a reading equal to 0.5 meters, which is below the low level thresholds that activate pumps PU1 and PU2 (4 and 1 meter, respectively). This results in both pumps working for the entire period of the attack, which lasts for 60 hours. Consequently, the water level in Tank T1 reaches the full tank level (6.5 meters), with the excess water being spilled. The adversary tries to conceal the surge in T1 water level with a second deception attack that alters the signal sent by PLC2 to SCADA with a time-varying offset.

Evaluation criteria

The attack detection algorithms were evaluated by comparing the detection report submitted by each team against the provided Test dataset. The assessment was based on two scores

that account for (1) the time taken to detect an attack, and (2) the classification accuracy. The two scores were eventually combined into an overall ranking score, as explained next.

Time-to-detection

The time-to-detection (TTD) is the time needed by an algorithm to disclose a threat. It is defined as the difference between the time t_d at which the attack is detected and the time t_0 at which the attack started:

$$TTD = t_d - t_0. \quad (1)$$

The value of t_d is inferred from the detection report, and it corresponds to the first time stamp flagged as ‘under attack’ while the attack is ongoing. The lower the value of TTD , the better the algorithm performs. If an attack is detected, we then have:

$$0 \leq TTD \leq \Delta t, \quad (2)$$

where Δt is the total duration of the attack. If the attack is not detected while it is ongoing (or at all), we set $TTD = \Delta t$. To facilitate the comparison of all algorithms under different attack scenarios, the following performance score (S_{TTD}) was computed:

$$S_{TTD} = 1 - \frac{1}{n_a} \sum_i^{n_a} \frac{TTD_i}{\Delta t_i}, \quad (3)$$

where n_a is the number of attacks contained in a dataset, TTD_i the time-to-detection relative to the i -th attack, and Δt_i the corresponding duration. S_{TTD} varies between 0 and 1, with $S_{TTD} = 1$ being the ideal case in which all attacks are immediately detected, and $S_{TTD} = 0$ the case in which none of the attacks is detected.

Classification performance

We determined the accuracy of an algorithm as its ability to disclose threats without raising false alarms. In the context of binary classification problems—like the BATADAL—the ability to identify threats is generally assessed with the *True Positive Rate* (TPR , also

known as *recall* or *sensitivity*), which is defined as:

$$TPR = \frac{TP}{TP + FN}, \quad (4)$$

where TP and FN represent the number of True Positives and False Negatives, respectively. In other words, the True Positive Rate is the ratio between the number of time steps correctly classified as under attack and the total number of time steps during which the system is under attack.

The ability to avoid false alarms is measured with the *True Negative Rate* (TNR , or *specificity*), defined as

$$TNR = \frac{TN}{FP + TN}, \quad (5)$$

where FP and TN represent the number of False Positives and True Negatives, respectively. The True Negative Rate is thus the ratio between the number of time steps correctly classified as safe conditions and the total number of time steps during which the system is in safe conditions.

To ease the comparison across all algorithms, the True Positive and True Negative Rate were combined into a single classification performance score (S_{CLF}), defined as the mean between TPR and TNR , namely:

$$S_{CLF} = \frac{TPR + TNR}{2}. \quad (6)$$

This score accounts for both correct detection and false alarms, so it is suited for binary classification problems in which the sample distribution is biased towards one of the two classes—i.e., safe conditions, in the BATADAL. The value of S_{CLF} varies between 0 and 1, with 1 representing a perfect classification.

Ranking score

The time-to-detection and accuracy scores were finally merged into an overall ranking score (S), defined as:

$$S = \gamma \cdot S_{TTD} + (1 - \gamma) \cdot S_{CLF}, \quad (7)$$

where γ ($0 \leq \gamma \leq 1$) determines the relative importance of the two evaluation scores. The coefficient γ was set to 0.5 for the analysis reported below; so, early detection and accurate classification were equally weighed. Note that a naïve detection mechanism that predicts the system to be always in safe conditions gets a score S equal to 0.25 ($S_{TTD} = 0$, $S_{CLF} = 0.5$). On the other hand, flagging the system as always under attack yields a value of S equal to 0.75 ($S_{TTD} = 1$, $S_{CLF} = 0.5$). This reflects the fact that S is intrinsically biased towards attack identification, since the consequences of failing to disclose an attack are deemed more costly than issuing false alarms. These naïve detection methods have the same value of S_{CLF} (equal to 0.5); yet, TPR and TNR are equal to 0 and 1 in the first case, and to 1 and 0 in the second case. This highlights the contrasting nature of the two components of S_{CLF} , and suggests how increased sensitivity may come at the cost of issuing more false alarms (and vice versa). Similarly, a potential conflict seems to exist between ensuring a timely detection of the attacks (high S_{TTD}) and issuing few false alarms, as recently pointed out by Housh and Ohar (2017c).

ATTACK DETECTION ALGORITHMS

Seven teams participated in the BATADAL. Here, we provide a brief description of each team’s attack detection algorithm.

- Aghashahi et al. (2017) adopted a two-stage method that first extracts a four-dimensional feature vector from the observed (multi-dimensional) time series data, and then constructs a classifier to detect attacks. In the first stage, the time periods of attack/no attack were used to extract four features that captured information on the covariance and mean structure. Here, for every time instance, a local neighbor-

hood is utilized to construct estimates of mean and covariance. In the second stage, a supervised classification technique (i.e., Random Forests, Breiman (2001)) was used to classify the system state as safe or under attack.

- Brentan et al. (2017) reduced the dimensionality of the problem by exploiting the division of C-Town network in District Metered Areas (DMAs). For each DMA, the authors used data on normal operating conditions to create Recurrent Neural Networks that forecast tank water levels as a function of pump flow, upstream pressure (of the corresponding pump station), and hour of the day (Díaz et al. 2016). A statistical control process was finally used to identify abrupt changes in the neural networks error time series when the latter were applied to data containing cyber attacks (Guralnik and Srivastava 1999). The rationale behind this approach is that it is plausible to expect an increase in the error time series when the system is under attack, since all neural networks are trained with data pertaining to normal operations.
- Chandy et al. (2017) developed two detection models running sequentially. The first one uses features of the SCADA data (e.g., combined flow of pump stations, volume pumped and stored) to check whether physical and/or operating rules have been violated (e.g., tank levels within the bounds, hydraulic relationships between nodes hold). The outcome of this model is a set of flagged events, which are confirmed by the second model. The latter is a Convolutional Variational Auto-Encoder—belonging to the family of deep learning methods (Kingma and Welling 2013; Doersch 2016)—that calculates the reconstruction probability of the data: the lower the probability, the higher the chance of the data being anomalous.
- Giacomoni et al. (2017) proposed two detection methods. The first one verifies the integrity of the actuator rules and SCADA data—by (1) checking whether the SCADA readings are consistent with the actuator rules defined for the water distribution system, and (2) comparing the data for all variables to identify values falling below or above thresholds created by analyzing data corresponding to normal operating

conditions. The second method builds on unveiling low-dimensionality components in the available data as well as the sparse nature of anomalies, thereby facilitating the separation of anomalies from the overall data. The separation of data into normal and anomalous components can be performed using principal component analysis (PCA) (Lakhina et al. 2004) or a convex optimization routine (Mardani et al. 2013). (The results reported below for Giacomoni et al. (2017) correspond to the second detection method based on PCA.)

- Abokifa et al. (2017) introduced a three-stage detection method, with each stage targeting a specific class of anomalies. The first step features outlier detection techniques to find statistical outliers in the data, thereby focusing on local anomalies that affect each sensor individually. The second stage employs an Artificial Neural Network—in the form of a Multi-Layer Perceptron—to detect contextual anomalies that do not conform to normal operating conditions. The third stage targets global anomalies that simultaneously affect multiple sensors. To disclose these anomalies, the layer uses Principal Component Analysis to decompose the high-dimensional datasets of sensor measurements into two sub-spaces representing normal and anomalous conditions (Lee et al. 2013).
- Pasha et al. (2017) presented an algorithm consisting of three main interconnected modules working on control rules and consistency checks, pattern recognition, and hydraulic and system relationships. The first module checks the consistency of the data against the set of control rules characterizing the water system, while the second one uses statistical analysis to identify patterns for single hydraulic parameters and combination thereof. The idea is that patterns under cyber attacks may not follow the original ones. The anomalous behaviors detected by the first two modules are finally confirmed by the third one, which develops relationships for some physical quantities (e.g., tank levels, flows) and compares their estimates against those reported by the first two modules.

- Housh and Ohar (2017b) proposed a model-based approach that employs EPANET to simulate the hydraulic processes of the water distribution systems, and then uses the error between EPANET simulated values and the available SCADA readings to detect anomalous behaviors. The approach consists of three main steps: first, available SCADA readings are used in a Mixed-Integer Linear Program to estimate the water demand in all nodes of C-Town; second, EPANET is used to generate reference values for the SCADA readings which are used to produce simulation errors when compared to actual readings; and third, a multi-level classification approach is implemented to classify the obtained simulation errors into event and normal conditions. A similar approach was successfully developed by Housh and Ohar (2017a) to detect contamination events in water distribution systems.

RESULTS

Algorithms performance

Table 4 reports the values of the ranking, time-to-detection, and classification score (S , S_{TTD} , and S_{CLF}) obtained by the competing algorithms on the test dataset. The table also reports the number of attacks detected, the values of TPR and TNR yielding the classification score, and the elements of the confusion matrix (i.e., TP , FP , TN , and FN). A visual comparison of S , S_{TTD} , and S_{CLF} is given in the scatter plot of Figure 3.

Figure 3 highlights a cluster of four high-performing algorithms, all achieving a ranking score S higher than (or close to) 0.90. The group is led by the algorithm proposed by Housh and Ohar (2017b), which shows the best overall performance ($S = 0.970$). Note that this algorithm is the top scorer in terms of both time-to-detection S_{TTD} and classification score S_{CLF} . Indeed, the detection trajectory depicted in Figure 4(a) shows that all attacks were immediately detected, with the exception of the last one, which was disclosed a few hours after its starting time. The algorithm of Abokifa et al. (2017) comes a close second, with S

equal to 0.949. This method was almost as quick as Housh and Ohar (2017b) in identifying the attacks, but it was more prone to false alarms. As shown in Figure 4(b), Abokifa et al. (2017) algorithm disclosed Attack #10 and #11 as a single continuous episode, erroneously flagging the system as under attack for the period in between. The algorithm proposed by Giacomoni et al. (2017) has the same TNR as that of Housh and Ohar (2017b)—meaning that both algorithms were the most successful in avoiding false alarms. However, Giacomoni et al. (2017) algorithm is less sensitive, resulting in lower TPR and minor timing errors (see Figure 4(c)) that led to a score S equal to 0.927. With a value of S equal to 0.896, the algorithm proposed by Brentan et al. (2017) can also be regarded as a strong performer. As shown in Figure 4(d), this algorithm was able to consistently and accurately detect most of the attacks, but it failed to identify the last one.

Although outdistanced by the leading group, the contributions of Chandy et al. (2017) and Pasha et al. (2017) are still sensibly better than the naïve detection mechanisms described in the second section. Their score S is equal to 0.802 and 0.773, respectively. As illustrated in Figure 4(e,f), these two detection algorithms appear to suffer from opposite problems. The algorithm of Chandy et al. (2017) turned out to be over-sensitive—meaning that it was able to identify most of the attack instances, but at the cost of issuing numerous false alarms. This is reflected on a relatively high value of the TPR , which, however, coincides with the lowest overall value of the TNR . On the other hand, the algorithm of Pasha et al. (2017) issued just a few false alarms, but it lacked sensitivity, thus failing to flag the system as under attack for the entire duration of the events. This resulted in a very high value of the TNR and the overall lowest TPR . Finally, the contribution of Aghashahi et al. (2017) detected only three attacks, leading to a score S equal to 0.534.

General Observations

The main insights from the results presented above can be summarized as follows:

- All algorithms but one achieved a ranking score S larger than 0.75, meaning that they performed better than naïve detection mechanisms. Yet, we observed a large variability in the algorithm performance.
- Both time-to-detection and classification score are important aspects of performance. Logically, the algorithms that performed consistently well for both metrics achieved a higher ranking score. There appears to be a strong correlation between these two metrics for most of the proposed algorithms (see Figure 3).
- Interestingly, the BATADAL was won by the only model-based approach. The idea of estimating the water demands to simulate system dynamics with EPANET, and then measure the errors with respect to the SCADA readings, proved successful. In this regard, it is important to note that the BATADAL demand patterns were fairly regular and consistent across the three datasets. Similarly, the participants were given the same computational model of the C-Town network that was used to generate the SCADA data (i.e., the input file *C-Town.inp*). Therefore, successful application of this approach in real-world settings might be hindered by various factors, such as the intrinsic variability of demand patterns, key uncertainties in the hydraulic model (e.g., actual status of each component, pipe roughness, or pump performance curves), or the unavailability of a reliable system model.
- Three data-driven algorithms belong to the cluster of high-performing detection mechanisms. This indicates that both model-based and data-driven approaches may be suitable for attack detection problems, although their performance would probably vary with the modelling context at hand.
- Only a few algorithms provided information on the attacked devices. Among these, the algorithms proposed by Brentan et al. (2017) and Giacomoni et al. (2017) were the most accurate.
- Most teams presented multi-stage detection methods. Comparing and confirming the detection issued by different modules can help decrease classification errors.

- Detection algorithms adopting a ‘multivariate’ approach may be best suited than algorithms analyzing a single time series per time. The inherent interdependence of the elements in the water network should theoretically allow for the detection of anomalies, even when the adversaries try to conceal their actions by altering the SCADA readings of one or a few deployed sensors. Note that such interdependence generally presents a nonlinear nature, which can be well described by nonlinear models—such as those belonging to the class of Artificial Neural Networks.
- The adoption of supervised classification algorithms that learn how to classify the system state (as either safe or under attack) may not be ideal, since the number of attacks in the available data is generally limited. Supervised classification algorithms should always be combined with cross-validation schemes.
- It appears that consistency checks and the analysis of control rules should lead to the identification of the simplest attacks.

We note that the results described above were obtained on three specific datasets, which represent only a small portion of the entire set of cyber-attacks that could threaten a water distribution system. Hence, the generation of different attacks is likely to produce different results—a limitation observed in other battles (e.g., Ostfeld et al. (2008)).

Another factor that influences the BATADAL results relates to the evaluation criteria. First, the time-to-detection score S_{TTD} is based on the ratio between the time taken to detect an attack and the attack duration; this implies that a 2-hour attack detected within 1 hour would have the same score as a 10-hour attack detected on hour 5. Some operators may prefer to define scores that account explicitly for the absolute value of the attack duration or its corresponding damage. Second, the classification performance score S_{CLF} is based on TPR and TNR , which are common metrics for classification problems. Yet, one may adopt other metrics, such as the $F1$ score (Sokolova and Lapalme 2009). Third, time-to-detection and classification performance score were given the same importance (the coefficient γ is equal to 0.50 in Eq. (7)). Depending on the problem at hand, one may want to outweigh

the time-to-detection (or the classification accuracy).

FUTURE RESEARCH DIRECTIONS

The BATADAL highlighted the following gaps that may need additional research efforts:

- *Robustness analysis.* As mentioned above, the performance of an attack detection algorithm may depend—to a certain extent—on the data used during the calibration and validation process. To limit the impact of data when evaluating the robustness of an algorithm, it is thus advisable to generate stochastic simulation scenarios comprising varying hydraulic conditions (i.e., water demand, initial tank levels) and multiple attack sequences.
- *Use of real SCADA data.* A major limitation of the current research on cyber-security is the absence of detailed information on cyber attacks to water utilities (e.g., timing, compromised devices, hydraulic response of the system). Access to such information and to the corresponding SCADA data—perhaps, in some anonymized forms—would drastically enhance our understanding on skills and limitations of detection algorithms. Another challenge with SCADA data is that they often contain noise and measurement errors, so attack detection algorithms should be coupled with data pre-processing techniques.
- *Pressure deficient conditions and water quality problems.* A limitation of this battle is its reliance of data generated with a demand-driven engine (Taormina et al. 2017). The range of attacks should be thus extended to include pressure-deficient conditions, water quality problems, and adversarial attempts aimed at threatening emergency responses, such as firefighting operations. In the absence of real SCADA data, simulated data could be generated by combining *epanetCPA* with more sophisticated hydraulic engines (e.g., Sayyed et al. (2015)) or water quality models (e.g., EPANET-MSX, Shang et al. (2007)).
- *Sensitivity analysis.* The definition of the cut-off criteria defining outliers regulates

the trade-off between TPR and TNR for most of the algorithms, so there is a need to adopt or develop sensitivity analysis tools that draw the appropriate line between normal and anomalous data (Abokifa et al. 2017). This step should always precede the application of an algorithm to new datasets—or its deployment in a SCADA system.

- *Computational requirements and scalability to large networks.* The algorithms presented in this paper were applied to a medium-sized water distribution system comprising one SCADA system and nine PLCs. Since attack detection algorithm are meant to run in real-time, it is necessary to evaluate their computational requirements as well as their scalability to larger networks.
- *Attack localization.* To facilitate and hasten incident resolution, an ideal detection mechanism should be able to identify which components of the network are being attacked. This is a rather challenging task due to the intrinsic correlation among the hydraulic variables. For data-driven detection mechanisms, the task may be solved with variable (or feature) selection algorithms (Galelli et al. 2014; Karakaya et al. 2016), which identify the variables that are strongly related to the detected anomalies.
- *Integration with other fault detection mechanisms.* Since attack detection mechanisms aim to disclose outliers and contextual anomalies in the system behavior, they may accidentally disclose anomalous behaviors that are not necessarily caused by cyber attacks (e.g., a water level sensor reporting wrong readings or a malfunctioning pump). Hence, there is a need to disclose the nature of each problem being identified—for example, by combining the attack detection algorithms with fault detection mechanisms that monitor the operations of PLCs.
- *Cost effectiveness of attack detection.* In the BATADAL, the different algorithms were evaluated based on their responsiveness and classification performance. Although these metrics provide some insights on the potential benefits of deploying an attack detection mechanism, a more comprehensive evaluation is needed. For example, one

could try to estimate the damage or cost associated to each cyber-physical attack and the corresponding cost savings guaranteed by a detection algorithm.

CLOSURE

The BATADAL is the first *battle competition* dealing with the emerging topic of cyber-physical security of water distribution systems. This battle gave an opportunity to develop, test, and compare attack detection algorithms for SCADA data. The solutions provided by seven teams suggest that timely and accurate detection can be obtained by both model-based and data-driven approaches, usually made of multiple sequential stages. While the data and algorithms presented here provide a first step towards an objective comparison of attack detection algorithms for water distribution systems, they do not represent the entire spectrum of modelling contexts that practitioners and researchers would encounter. Hence, we hope that the availability of a dedicated website (www.batadal.net) will help share more datasets and case studies.

SUPPLEMENTAL DATA

The supplemental data include the following files, which are available online in the ASCE Library (www.ascelibrary.org):

- *BATADAL rules.pdf*—competition rules, available to participants;
- *C-Town.inp*—EPANET input file, version 2.00.12, available to participants;
- *Training dataset 1.csv*—data without attacks, available to participants;
- *Training dataset 2.csv*—data with attacks and corresponding labels, available to the participants with partial labels;
- *Test dataset.csv*—data with attacks and corresponding labels, available to the participants without labels;
- *Detection Reports.zip*—detection reports submitted by the participants.

Additional details about BATADAL are available at www.batadal.net. *epanetCPA* is available at <https://github.com/rtaormina/epanetCPA>.

ACKNOWLEDGEMENTS

Riccardo Taormina, Stefano Galelli, and Nils Ole Tippenhauer are supported by the National Research Foundation (NRF), Singapore, under its National Cybersecurity R&D Programme (Award No. NRF2014NCR-NCR001-40). Demetrios Eliades is supported by the European Union’s Horizon 2020 research and innovation programme under grant agreement No. 739551 (KIOS CoE). Mohsen Aghashahi and M. Katherine Banks are supported by Qatar National Research Fund (QNRF) under the grant NPRP8-1292-2-548. B. M. Brentan, Enrique Campbell, G. Lima, D. Manzi, D. Ayala-Cabrera, M. Herrera, I. Montalvo, J. Izquierdo, and E. Luvizotto Jr. are supported CAPES and CNPq founding agencies. Ahmed Abokifa, Kelsey Haddad, Cynthia Lo, and Pratim Biswas’ work was carried out with the partial support from the Lucy and Stanley Lopata Endowment at Washington University in St. Louis.

REFERENCES

- Abokifa, A. A., Haddad, K., Lo, C. S., and Biswas, P. (2017). “Detection of cyber physical attacks on water distribution systems via principal component analysis and artificial neural networks.” *World Environmental and Water Resources Congress 2017*, 676–691, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.063>>.
- Adepu, S., Mishra, G., and Mathur, A. (2017). “Access control in water distribution networks: A case study.” *Software Quality, Reliability and Security (QRS), 2017 IEEE International Conference on*, IEEE, 184–191.
- Aghashahi, M., Sundararajan, R., Pourahmadi, M., and Banks, M. K. (2017). “Water distribution systems analysis symposium; battle of the attack detection algorithms (BATADAL).” *World Environmental and Water Resources Congress 2017*, 101–108, <<http://ascelibrary.org/doi/abs/10.1061/9780784480595.010>>.
- Anderson, R. J. (2010). *Security engineering: a guide to building dependable distributed systems*. John Wiley & Sons.
- Breiman, L. (2001). “Random forests.” *Machine Learning*, 45(1), 5–32.
- Brentan, B. M., Campbell, E., Lima, G., Manzi, D., Ayala-Cabrera, D., Herrera, M., Montalvo, I., Izquierdo, J., and Luvizotto, E. (2017). “On-line cyber attack detection in water networks through state forecasting and control by pattern recognition.” *World Environmental and Water Resources Congress 2017*, 583–592, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.054>>.
- Cardenas, A., Amin, S., Sinopoli, B., Giani, A., Perrig, A., and Sastry, S. (2009). “Challenges for securing cyber physical systems.” *Proceedings of Workshop on future directions in cyber-physical systems security*, Vol. 5.
- Cardenas, A. A., Amin, S., and Sastry, S. (2008). “Secure control: Towards survivable cyber-physical systems.” *Proceedings of Conference on Distributed Computing Systems Workshops (ICDCS)*, IEEE, 495–500.
- Chandy, S. E., Rasekh, A., Barker, Z. A., Campbell, B., and Shafiee, M. E. (2017). “De-

- tection of cyber-attacks to water systems through machine-learning-based anomaly detection in scada data.” *World Environmental and Water Resources Congress 2017*, 611–616, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.057>>.
- Díaz, S., González, J., and Mínguez, R. (2016). “Uncertainty evaluation for constrained state estimation in water distribution systems.” *Journal of Water Resources Planning and Management*, 142(12), 06016004.
- Doersch, C. (2016). “Tutorial on variational autoencoders.” *arXiv preprint:1606.05908*.
- Galelli, S., Humphrey, G. B., Maier, H. R., Castelletti, A., Dandy, G. C., and Gibbs, M. S. (2014). “An evaluation framework for input variable selection algorithms for environmental data-driven models.” *Environmental Modelling & Software*, 62, 33–51.
- Giacomoni, M., Gatsis, N., and Taha, A. (2017). “Identification of cyber attacks on water distribution systems by unveiling low-dimensionality in the sensory data.” *World Environmental and Water Resources Congress 2017*, 660–675, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.062>>.
- Gong, W., Suresh, M. A., Smith, L., Ostfeld, A., Stoleru, R., Rasekh, A., and Banks, M. K. (2016). “Mobile sensor networks for optimal leak and backflow detection and localization in municipal water networks.” *Environmental Modelling & Software*, 80, 306–321.
- Graham, J., Olson, R., and Howard, R. (2016). *Cyber security essentials*. CRC Press.
- Guralnik, V. and Srivastava, J. (1999). “Event detection from time series data.” *Proceedings of the fifth ACM SIGKDD international conference on Knowledge discovery and data mining*, ACM, 33–42.
- Hayes, M. A. and Capretz, M. A. (2015). “Contextual anomaly detection framework for big sensor data.” *Journal of Big Data*, 2(1), 2.
- Hill, D., Kerkez, B., Rasekh, A., Ostfeld, A., Minsker, B., and Banks, M. K. (2014). “Sensing and cyberinfrastructure for smarter water management: the promise and challenge of ubiquity.” *Journal of Water Resources Planning and Management*, 140(7), 01814002.
- Housh, M. and Ohar, Z. (2017a). “Integrating physically based simulators with event detec-

- tion systems: Multi-site detection approach.” *Water Research*, 110, 180–191.
- Housh, M. and Ohar, Z. (2017b). “Model based approach for cyber-physical attacks detection in water distribution systems.” *World Environmental and Water Resources Congress 2017*, 727–736, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.067>>.
- Housh, M. and Ohar, Z. (2017c). “Multiobjective calibration of event-detection systems.” *Journal of Water Resources Planning and Management*, 143(8), 06017004.
- ICS-CERT (2014). “NCCIC/ICS-CERT year in review: FY 2013.” *Report No. 13-50369*, U.S. Department of Homeland Security – Industrial Control Systems-Cyber Emergency Response Team, Washington, D.C.
- ICS-CERT (2015). “NCCIC/ICS-CERT year in review: FY 2014.” *Report No. 14-50426*, U.S. Department of Homeland Security – Industrial Control Systems-Cyber Emergency Response Team, Washington, D.C.
- ICS-CERT (2016). “NCCIC/ICS-CERT year in review: FY 2015.” *Report No. 15-50569*, U.S. Department of Homeland Security – Industrial Control Systems-Cyber Emergency Response Team, Washington, D.C.
- Karakaya, G., Galelli, S., Ahipaşaoğlu, S. D., and Taormina, R. (2016). “Identifying (quasi) equally informative subsets in feature selection problems for classification: a max-relevance min-redundancy approach.” *IEEE Transactions on Cybernetics*, 46(6), 1424–1437.
- Kingma, D. P. and Welling, M. (2013). “Auto-encoding variational bayes.” *arXiv preprint:1312.6114*.
- Lakhina, A., Crovella, M., and Diot, C. (2004). “Diagnosing network-wide traffic anomalies.” *Proceedings of the 2004 Conference on Applications, Technologies, Architectures, and Protocols for Computer Communications*, SIGCOMM ’04, 219–230, <<http://doi.acm.org/10.1145/1015467.1015492>>.
- Lee, Y.-J., Yeh, Y.-R., and Wang, Y.-C. F. (2013). “Anomaly detection via online oversampling principal component analysis.” *IEEE Transactions on Knowledge and Data Engineering*, 25(7), 1460–1470.

- Mardani, M., Mateos, G., and Giannakis, G. B. (2013). “Recovery of low-rank plus compressed sparse matrices with application to unveiling traffic anomalies.” *IEEE Transactions on Information Theory*, 59(8), 5186–5205.
- Ostfeld, A., Salomons, E., Ormsbee, L., Uber, J. G., Bros, C. M., Kalungi, P., Burd, R., Zazula-Coetzee, B., Belrain, T., Kang, D., et al. (2011). “Battle of the water calibration networks.” *Journal of Water Resources Planning and Management*, 138(5), 523–532.
- Ostfeld, A., Uber, J. G., Salomons, E., Berry, J. W., Hart, W. E., Phillips, C. A., Watson, J.-P., Dorini, G., Jonkergouw, P., Kapelan, Z., et al. (2008). “The battle of the water sensor networks (bwsn): A design challenge for engineers and algorithms.” *Journal of Water Resources Planning and Management*, 134(6), 556–568.
- Pasha, M. F. K., Kc, B., and Somasundaram, S. L. (2017). “An approach to detect the cyber-physical attack on water distribution system.” *World Environmental and Water Resources Congress 2017*, 703–711, <<http://ascelibrary.org/doi/abs/10.1061/9780784480625.065>>.
- Rasekh, A., Hassanzadeh, A., Mulchandani, S., Modi, S., and Banks, M. K. (2016). “Smart water networks and cyber security.” *Journal of Water Resources Planning and Management*, 142.
- Rossman, L. A. (2000). *EPANET 2 Users Manual*. U.S. Environmental Protection Agency, Washington, D.C., EPA/600/R-00/057 edition.
- Sayyed, M. A. H. A., Gupta, R., and Tanyimboh, T. T. (2015). “Noniterative application of epanet for pressure dependent modelling of water distribution systems.” *Water Resources Management*, 29(9), 3227–3242.
- Shang, F., Uber, J. G., and Rossman, L. A. (2007). “Modeling reaction and transport of multiple species in water distribution systems.” *Environmental Science & Technology*, 42(3), 808–814.
- Sokolova, M. and Lapalme, G. (2009). “A systematic analysis of performance measures for classification tasks.” *Information Processing & Management*, 45(4), 427–437.
- Sønderlund, A. L., Smith, J. R., Hutton, C. J., Kapelan, Z., and Savic, D. (2016). “Ef-

fectiveness of smart meter-based consumption feedback in curbing household water use:
Knowns and unknowns.” *Journal of Water Resources Planning and Management*, 142(12),
04016060.

Taormina, R., Galelli, S., Tippenhauer, N. O., Salomons, E., and Ostfeld, A. (2017). “Charac-
terizing cyber-physical attacks on water distribution systems.” *Journal of Water Resources
Planning and Management*, 143(5), 04017009.

The Times of Israel (2018). “Israel tech to protect NY water systems from
cyberattacks, <[https://www.timesofisrael.com/israel-tech-to-protect-ny-water-systems-
from-attack/](https://www.timesofisrael.com/israel-tech-to-protect-ny-water-systems-from-attack/)> (January).

Urbina, D., Giraldo, J., Tippenhauer, N. O., and Cárdenas, A. (2016). “Attacking fieldbus
communications in ICS: Applications to the SWaT testbed.” *Proceedings of Singapore
Cyber Security Conference (SG-CRC)* (January).

U.S. Department of Homeland Security (2017). “Critical infrastructure sectors,
<<https://www.dhs.gov/critical-infrastructure-sectors>> (September).

TABLE 1. Sensors and actuators (pumps, valves) monitored/controlled by the PLCs. For each PLC, we also report the corresponding controlling sensor, which provides the information needed to operate the actuators. Note that a PLC-to-PLC connection is established whenever an actuator and the corresponding control sensor are connected to two different PLCs.

PLC	Sensor	Actuators (Controlling sensor)
PLC1	-	PU1(T1), PU2(T1)
PLC2	T1	-
PLC3	T2	V2(T2), PU4(T3), PU5(T3), PU6(T4), PU7(T4)
PLC4	T3	-
PLC5	-	PU8(T5), PU9(-), PU10(T7), PU11(T7)
PLC6	T4	-
PLC7	T5	-
PLC8	T6	-
PLC9	T7	-

TABLE 2. Attacks featured in Training dataset 2.

ID	Starting time [dd/mm/YY HH]	Ending time [dd/mm/YY HH]	Duration [hours]	Attack description	SCADA concealment	Labeled [hours]
1	13/09/2016 23	16/09/2016 00	50	Attacker alters SCADA transmission to PLC9 and changes the L_T7 thresholds determining when pumps PU10/PU11 are switched ON/OFF. Low levels in T7.	Replay attack on L_T7 .	42
2	26/09/2016 11	27/09/2016 10	24	Like Attack #1.	Like Attack #1 but re-play attack extended on PU10/PU11 flow and status.	0
3	09/10/2016 09	11/10/2016 20	60	Attack alters L_T1 readings sent by PLC2 to PLC1, which reads a constant low level and keeps pumps PU1/PU2 ON. Overflow in T1.	Polyline to offset L_T1 increase.	60
4	29/10/2016 19	02/11/2016 16	94	Like Attack #3.	Replay attack on L_T1, PU1/PU2 flow and status, as well as on pressure at pumps outlet (P_J269).	37
5	26/11/2016 17	29/11/2016 04	60	Working speed of PU7 reduced to 0.9 of nominal speed. Lower water levels in T4.		7
6	06/12/2016 07	10/12/2016 04	94	Like Attack #5, but speed reduced to 0.7.	Replay attack on L_T4.	73
7	14/12/2016 15	19/12/2016 04	110	Like Attack #6.	Replay attack on L_T4, as well as on PU6/PU7 flow and status.	0

TABLE 3. Attacks featured in the Test dataset.

ID	Starting time [dd/mm/YY HH]	Ending time [dd/mm/YY HH]	Duration [hours]	Attack description	SCADA concealment
8	16/01/2017 09	19/01/2017 06	70	Attacker gains control of PLC3 and changes the L_T3 thresholds determining when pumps PU4/PU5 are switched ON/OFF. Low levels in T3.	Replay attack on L_T3, as well as on PU4/PU5 flow and status.
9	30/01/2017 08	02/02/2017 00	65	Attack alters L_T2 readings arriving to PLC3, which reads a low level and keeps valve V2 OPEN. The attack leads T2 to overflow.	Polyline to offset L_T2 increase.
10	09/02/2017 03	10/02/2017 09	31	Malicious activation of pump PU3	
11	12/02/2017 01	13/02/2017 07	31	Similar to Attack #10	
12	24/02/2017 05	28/02/2017 08	100	Similar to Attack #9	Replay attack on L_T2, V2 flow and status, as well as on V2 inlet and outlet pressure readings (P_J14, P_J422)
13	10/03/2017 14	13/03/2017 21	80	Attacker gains control of PLC5 and changes the L_T7 thresholds determining when pumps PU10/PU11 are switched ON/OFF. The pumps are forced to switch ON/OFF continuously during the attack.	Replay attack on L_T7, PU10/PU11 flow and status, as well as on pumps inlet and outlet pressure readings (P_J14, P_J422). Inlet pressure concealment terminates before that of other variables.
14	25/03/2017 20	27/03/2017 01	30	Alteration of T4 signal arriving to PLC6. Overflow in T6.	

TABLE 4. Performance of all attack detection algorithms, assessed in terms of number of attacks detected, overall ranking score (S), time-to-detection (S_{TTD}), accuracy (S_{CLF}), True Positive Ratio (TPR), True Negative Ratio (TNR), and number of True Positives (TP), False Positives (FP), True Negatives (TN) and False Negatives (FN). The algorithms are ranked according to the their overall ranking score.

Rank	Team	# Attacks detected	S	S_{TTD}	S_{CLF}	TPR	TNR	TP	FP	TN	FN
1	Housh and Ohar	7	0.970	0.965	0.975	0.953	0.997	388	5	1677	19
2	Abokifa et al.	7	0.949	0.958	0.940	0.921	0.959	375	69	1613	32
3	Giacomoni et al.	7	0.927	0.936	0.917	0.838	0.997	341	5	1677	66
4	Brentan et al.	6	0.894	0.857	0.931	0.889	0.973	362	45	1637	45
5	Chandy et al.	7	0.802	0.835	0.768	0.857	0.678	349	541	1141	58
6	Pasha et al.	7	0.773	0.885	0.660	0.329	0.992	134	14	1668	273
7	Aghashahi et al.	3	0.534	0.429	0.640	0.396	0.884	161	195	1487	246

618	List of Figures	
619	1 Graphical representation of C-Town water distribution system	33
620	2 Illustration of attack #3 (from Training dataset 2). The attacker alters Tank	
621	T1 water level readings (continuous black line) sent by PLC2 to PLC1, which	
622	reads a constant low level (dotted black line) and keeps Pumps PU1/PU2 ON.	
623	This causes an overflow in Tank T1 (thick gray line). To conceal the action,	
624	the attacker alters the signal sent by PLC2 to SCADA (dashed black line)	
625	by adding a time-varying offset (continuous gray line). The duration of the	
626	entire attack is highlighted by the light gray line on the horizontal axis. . . .	34
627	3 Graphical representation of the algorithm performance	35
628	4 Comparison between actual and detected attacks	36




FIG. 1. Graphical representation of C-Town water distribution system (adapted from Taormina et al. 2017).




FIG. 2. Illustration of attack #3 (from Training dataset 2). The attacker alters Tank T1 water level readings (continuous black line) sent by PLC2 to PLC1, which reads a constant low level (dotted black line) and keeps Pumps PU1/PU2 ON. This causes an overflow in Tank T1 (thick gray line). To conceal the action, the attacker alters the signal sent by PLC2 to SCADA (dashed black line) by adding a time-varying offset (continuous gray line). The duration of the entire attack is highlighted by the light gray line on the horizontal axis.




FIG. 3. Graphical representation of the algorithm performance, measured in terms of time-to-detection (S_{TTD} , horizontal axis), classification performance (S_{CLF} , vertical axis), and overall ranking score (S , color-bar).